

CLIENT INFORMATION

Client: *****

Requested On: Sep 10, 2025

Phone: *****

Email: *****

Kitting, Logistics, and Support provided by: SimpleLab, Inc.

Questions? For fastest assistance:

support@mytapscore.com

Do not contact facility technicians directly.

TESTING PERFORMED

Testing Requested: Advanced City Water Test

Matrix: Drinking Water

Testing / Report ID: VCY2YS

Testing Facility: Microbac Laboratories

Facility Location: 61 Louisa Viens Drive
Dayville, Connecticut 06241

SAMPLE INFORMATION

Collection Date: Aug 19, 2026

Collected By: *****

Received Date: Aug 21, 2026

Reported On: Aug 28, 2026

Sample Location: Kitchen faucet

Sample Address: *****

TESTING NOTES FROM TAP SCORE

There were no problems with analytical events associated with this report unless noted. Quality control data is within laboratory defined or method specified acceptance limits except where noted. If you have any questions regarding these test results, please contact support@mytapscore.com

SUMMARY ANALYSIS

ANALYTE	UNIT	RESULT	METHOD	EVALUATION
pH	pH	7.6	SM 4500-H+B	OK
Total Dissolved Solids	PPM	284	SM 2510 B	No benchmark available
Hardness	PPM	46.1	SM 2340 B	No benchmark available
Expanded Hardness	PPM	47.6	Calculation	No benchmark available
Grains per gallon	Grains	2.7	Calculation	No benchmark available
Alkalinity (as CaCO ₃)	PPM	63.4	SM 2320 B	No benchmark available
Langelier Saturation Index		-1.1	Calculation	No benchmark available
Sodium Adsorption Ratio		4.75	Calculation	No benchmark available
Total THMs	PPB	NOT DETECTED	Calculation	No evaluation possible

TEST RESULTS

ANALYTE	UNIT	RESULT	MDL	RL	METHOD	EVALUATION
1,1,1,2 Tetrachloroethane	PPB	Below Reporting Limit	0.21	0.5	EPA 524.2	No evaluation possible
1,1,1 Trichloroethane	PPB	Below Reporting Limit	0.08	0.5	EPA 524.2	No evaluation possible
1,1,2,2 Tetrachloroethane	PPB	Below Reporting Limit	0.1	0.5	EPA 524.2	No evaluation possible
1,1,2 Trichloroethane	PPB	Below Reporting Limit	0.15	0.5	EPA 524.2	No evaluation possible
1,1 Dichloroethane	PPB	Below Reporting Limit	0.11	0.5	EPA 524.2	No evaluation possible
1,1 Dichloroethylene	PPB	Below Reporting Limit	0.15	0.5	EPA 524.2	No evaluation possible

Use of this report can only be done in full, with no alterations or additions. Tap Score maintains the right to enforce this and by accepting this report you agree to abide by this policy.

1,1 Dichloropropene	PPB	Below Reporting Limit	0.17	0.5	EPA 524.2	No evaluation possible
1,2,3 Trichlorobenzene	PPB	Below Reporting Limit	0.08	0.5	EPA 524.2	No evaluation possible
1,2,3 Trichloropropane	PPB	Below Reporting Limit	0.21	0.5	EPA 524.2	No evaluation possible
1,2,4 Trichlorobenzene	PPB	Below Reporting Limit	0.24	0.5	EPA 524.2	No evaluation possible
1,2,4 Trimethylbenzene	PPB	Below Reporting Limit	0.11	0.5	EPA 524.2	No evaluation possible
1,2 Dichlorobenzene	PPB	Below Reporting Limit	0.13	0.5	EPA 524.2	No evaluation possible
1,2 Dichloroethane	PPB	Below Reporting Limit	0.08	0.5	EPA 524.2	No evaluation possible
1,2 Dichloropropane	PPB	Below Reporting Limit	0.13	0.5	EPA 524.2	No evaluation possible
1,3,5 Trimethylbenzene	PPB	Below Reporting Limit	0.1	0.5	EPA 524.2	No evaluation possible
1,3 Dichlorobenzene	PPB	Below Reporting Limit	0.12	0.5	EPA 524.2	No evaluation possible
1,3 Dichloropropane	PPB	Below Reporting Limit	0.14	0.5	EPA 524.2	No evaluation possible
1,4 Dichlorobenzene	PPB	Below Reporting Limit	0.1	0.5	EPA 524.2	No evaluation possible
2,2 Dichloropropane	PPB	Below Reporting Limit	0.21	0.5	EPA 524.2	No evaluation possible
Aluminum	PPM	Below Reporting Limit	0.0083	0.051	EPA 200.7	No evaluation possible
Antimony	PPM	Below Reporting Limit	0.00019	0.001	EPA 200.8	No evaluation possible
Arsenic	PPM	Below Reporting Limit	5.0E-5	0.00102	EPA 200.8	No evaluation possible
Barium	PPM	0.0159	8.0E-5	0.00102	EPA 200.8	< HGL
Benzene	PPB	Below Reporting Limit	0.13	0.5	EPA 524.2	No evaluation possible
Beryllium	PPM	Below Reporting Limit	1.0E-5	0.001	EPA 200.8	No evaluation possible
Bicarbonate	PPM	77				No benchmark available
Boron	PPM	0.0197	0.00209	0.0051	EPA 200.7	< HGL
Bromobenzene	PPB	Below Reporting Limit	0.18	0.5	EPA 524.2	No evaluation possible
Bromochloromethane	PPB	Below Reporting Limit	0.11	0.5	EPA 524.2	No evaluation possible
Bromodichloromethane	PPB	Below Reporting Limit	0.09	0.5	EPA 524.2	No evaluation possible
Bromoform	PPB	Below Reporting Limit	0.11	0.5	EPA 524.2	No evaluation possible
Bromomethane	PPB	Below Reporting Limit	0.24	0.5	EPA 524.2	No evaluation possible
Cadmium	PPM	Below Reporting Limit	2.0E-5	0.0004	EPA 200.8	No evaluation possible
Calcium	PPM	13.6	0.0351	0.05	EPA 200.7	No benchmark available
Carbonate	PPM	0.141				No benchmark available
Carbon Tetrachloride	PPB	Below Reporting Limit	0.16	0.5	EPA 524.2	No evaluation possible
Chloride	PPM	104	0.692	2	EPA 300.0	No benchmark available
Chloride-to-Sulfate Mass Ratio		10.9				No benchmark available
Chlorobenzene	PPB	Below Reporting Limit	0.08	0.5	EPA 524.2	No evaluation possible
Chloroethane	PPB	Below Reporting Limit	0.18	0.5	EPA 524.2	No evaluation possible
Chloroform	PPB	Below Reporting Limit	0.17	0.5	EPA 524.2	No evaluation possible
Chloromethane	PPB	Below Reporting Limit	0.13	0.5	EPA 524.2	No evaluation possible
Chlorotoluene 2	PPB	Below Reporting Limit	0.08	0.5	EPA 524.2	No evaluation possible
Chlorotoluene 4	PPB	Below Reporting Limit	0.12	0.5	EPA 524.2	No evaluation possible
Chromium (Total)	PPM	Below Reporting Limit	5.0E-5	0.00102	EPA 200.8	No evaluation possible
cis 1,2 Dichloroethylene	PPB	Below Reporting Limit	0.2	0.5	EPA 524.2	No evaluation possible
cis 1,3 Dichloropropene	PPB	Below Reporting Limit	0.13	0.5	EPA 524.2	No evaluation possible
Cobalt	PPM	Below Reporting Limit	1.0E-5	0.00102	EPA 200.8	No evaluation possible
Copper	PPM	0.0229	0.00037	0.00102	EPA 200.8	< HGL
Dibromochloromethane	PPB	Below Reporting Limit	0.14	0.5	EPA 524.2	No evaluation possible
Dibromochloropropane	PPB	Below Reporting Limit	0.15	0.5	EPA 524.2	No evaluation possible

Use of this report can only be done in full, with no alterations or additions. Tap Score maintains the right to enforce this and by accepting this report you agree to abide by this policy.

Dibromomethane	PPB	Below Reporting Limit	0.18	0.5	EPA 524.2	No evaluation possible
Dichlorodifluoromethane	PPB	Below Reporting Limit	0.12	0.5	EPA 524.2	No evaluation possible
Dichloromethane	PPB	Below Reporting Limit	0.31	0.5	EPA 524.2	No evaluation possible
Ethylbenzene	PPB	Below Reporting Limit	0.08	0.5	EPA 524.2	No evaluation possible
Ethylene dibromide	PPB	Below Reporting Limit	0.1	0.5	EPA 524.2	No evaluation possible
Fluoride	PPM	Below Reporting Limit	0.038	0.1	EPA 300.0	No evaluation possible
Hexachlorobutadiene	PPB	Below Reporting Limit	0.2	0.5	EPA 524.2	No evaluation possible
Iron	PPM	Below Reporting Limit	0.00565	0.05	EPA 200.7	No evaluation possible
Isopropylbenzene	PPB	Below Reporting Limit	0.11	0.5	EPA 524.2	No evaluation possible
Lead	PPM	Below Reporting Limit	6.0E-5	0.0004	EPA 200.8	No evaluation possible
Lithium	PPM	Below Reporting Limit	0.00555	0.051	EPA 200.7	No evaluation possible
Magnesium	PPM	2.98	0.00896	0.051	EPA 200.7	No benchmark available
Manganese	PPM	Below Reporting Limit	0.00027	0.00102	EPA 200.8	No evaluation possible
Mercury	PPM	Below Reporting Limit	0.00013	0.0002	EPA 200.8	No evaluation possible
Methyl Tertiary Butyl Ether	PPB	Below Reporting Limit	0.24	0.5	EPA 524.2	No evaluation possible
Molybdenum	PPM	Below Reporting Limit	2.0E-5	0.00102	EPA 200.8	No evaluation possible
m,p Xylene	PPB	Below Reporting Limit	0.13	0.5	EPA 524.2	No evaluation possible
Naphthalene	PPB	Below Reporting Limit	0.1	0.5	EPA 524.2	No evaluation possible
n Butylbenzene	PPB	Below Reporting Limit	0.17	0.5	EPA 524.2	No evaluation possible
Nickel	PPM	Below Reporting Limit	0.00023	0.001	EPA 200.8	No evaluation possible
Nitrate (as N)	PPM	0.464	0.043	0.1	EPA 300.0	< HGL
Nitrite (as N)	PPM	Below Reporting Limit	0.047	0.1	EPA 300.0	No evaluation possible
n Propylbenzene	PPB	Below Reporting Limit	0.1	0.5	EPA 524.2	No evaluation possible
o Xylene	PPB	Below Reporting Limit	0.11	0.5	EPA 524.2	No evaluation possible
Phosphorus	PPM	Below Reporting Limit	0.0101	1.02	EPA 200.7	No evaluation possible
p Isopropyltoluene	PPB	Below Reporting Limit	0.11	0.5	EPA 524.2	No evaluation possible
Potassium	PPM	3.73	0.0437	0.204	EPA 200.7	No benchmark available
sec Butylbenzene	PPB	Below Reporting Limit	0.15	0.5	EPA 524.2	No evaluation possible
Selenium	PPM	Below Reporting Limit	0.00019	0.0051	EPA 200.8	No evaluation possible
Silver	PPM	Below Reporting Limit	2.0E-5	0.00102	EPA 200.8	No evaluation possible
Sodium	PPM	74.3	0.377	1.02	EPA 200.7	No benchmark available
Specific Conductivity	umhos/cm	486	1.77	1	SM 2510 B	No benchmark available
Strontium	PPM	0.139	0.00035	0.0102	EPA 200.7	< HGL
Styrene	PPB	Below Reporting Limit	0.14	0.5	EPA 524.2	No evaluation possible
Sulfate	PPM	9.54	0.317	1	EPA 300.0	< HGL
tert Butylbenzene	PPB	Below Reporting Limit	0.16	0.5	EPA 524.2	No evaluation possible
Tetrachloroethylene	PPB	Below Reporting Limit	0.13	0.5	EPA 524.2	No evaluation possible
Thallium	PPM	Below Reporting Limit	2.0E-5	0.0004	EPA 200.8	No evaluation possible
Tin	PPM	Below Reporting Limit	0.00015	0.00408	EPA 200.8	No evaluation possible
Titanium	PPM	Below Reporting Limit	0.00093	0.00204	EPA 200.7	No evaluation possible
Toluene	PPB	Below Reporting Limit	0.12	0.5	EPA 524.2	No evaluation possible
trans 1,3 Dichloropropene	PPB	Below Reporting Limit	0.11	0.5	EPA 524.2	No evaluation possible
Trichloroethylene	PPB	Below Reporting Limit	0.17	0.5	EPA 524.2	No evaluation possible
Trichlorofluoromethane	PPB	Below Reporting Limit	0.1	0.5	EPA 524.2	No evaluation possible
Uranium	PPM	Below Reporting Limit	1.0E-5	0.001	EPA 200.8	No evaluation possible

Use of this report can only be done in full, with no alterations or additions. Tap Score maintains the right to enforce this and by accepting this report you agree to abide by this policy.

Vanadium	PPM	Below Reporting Limit	3.0E-5	0.00102	EPA 200.8	No evaluation possible
Vinyl Chloride	PPB	Below Reporting Limit	0.07	0.5	EPA 524.2	No evaluation possible
Zinc	PPM	0.734	0.00267	0.0051	EPA 200.7	< HGL

How To Read Your Tap Score PDF Report

Your results are being evaluated against the Health Guidance Level.
 This is a health protective, non-enforceable drinking water benchmark. HGL is based on the most protective human health benchmark used among public health agencies for a contaminant. Drinking water at or near the HGL over the course of your lifetime is thought to be safe.

MDL: The Method Detection Limit is the lowest concentration which the analysis team and instrumentation is configured to measure.
 RL: The Method Reporting Limit is the lowest level at which the laboratory can confidently and accurately quantify the concentration.

Use of this report can only be done in full, with no alterations or additions. Tap Score maintains the right to enforce this and by accepting this report you agree to abide by this policy.



Did you know?

This Tap Score report is easier to understand when viewed online. Access in-depth information about every detection, including health risks and treatment solutions.

app.mytapscore.com/signin